

Hubert Enviro Care Systems (P) Ltd.

18, 92nd Street, Ashok Nagar,
Chennai - 600 083.
Ph: 42985555 Fax : 42985500
E-mail : labsales@hecs.in

Laboratory Services Division
Accredited by NABL in the fields
of Chemical & Biological Testing
Recognized by MoEF.
FSSAI Notified Laboratory
ISO 9001, 14001 & OHSAS 18001 Certified.

TEST REPORT

Page : 1 of 1

Name of the Client : M/s. Strides Shasun Limited.,
Address of the Client : A1/B Sipcot Industrial Complex,
Kudikadu,
Cuddalore-607 005.
Sample Description : Stack Emission
Sample Mark : Boiler Stack
Sample Drawn By : Hubert Enviro Care Systems Pvt Ltd
Sampling/received Date : 27/10/2017 -28/10/2017
Analysis Commenced On : 28/10/2017

Report No. : HECSL/ST/009/281017
Report Date : 06/11/2017

Completed On : 06/11/2017

S.No.	Parameters	Units	Results	Test Method	Standards
1	Stack Temperature	° C	165	IS 11255 (P-3)2008	-
2	Flow rate of stack gases	Nm ³ /hr	16512	IS 11255 (P-3) 2008	-
3	Particulate Matter	mg/Nm ³	34.62	IS 11255 (P-1) 1985(Reaff 2003)/EPA 5	150
4	Sulphur Dioxide	mg/Nm ³	12.87	IS 11255 (P-2)1985(Reaff:2003)	-
5	Nitrogen Dioxide	mg/Nm ³	151.36	IS 11255 (P-7) 2005	-
6	Carbon monoxide	%V/V	BDL(DL 0.2)	IS 13270 -1992(Reaff:2009)	1%
7	Carbon diOxide	%V/V	4.8	IS 13270 -1992(Reaff:2009)	-
8	Oxygen	% V/V	17.0	IS 13270 -1992(Reaff:2009)	-

Note:-BDL - Below Detection Limit, D.L- Detection Limit, Nm³/hr- Normal cubic meter per hour,
mg/Nm³- Milligrams per Normal cubic meter, %V/V- Percentage Volume per Volume.

Remarks: No direct TNPCB / CPCB Limits for the above parameters; meets as per MoEF standards, where applicable.

End of Report



C.P. Sivaraman
Authorized Signatory

C.P. SIVARAMAN
Laboratory Manager